Information requirements for heat pump space heaters and heat pump combination heaters - Commission Regulation (EU) No 813/2013

Indoor Unit Model	Vitocal 151-A AWOT-M-E-AC-AF 151.A16
Outdoor Unit Model	Vitocal 15X-A ODU 230V A16 AF
Equipped with a supplementary heater	yes
Heat pump combination heater	ves

Application	Low temperature
Climate conditions	Average



Rated heat output	Prated	14	kW
Declared capacity for heating for part load at indoor temper	rature 20 °C and	d outdoor	
temperature Tj			
T _j = - 7 °C	Pdh	12.0	kW
T _j = + 2 °C	Pdh	7.4	kW
T _j = + 7 °C	Pdh	6.7	kW
T _j = + 12 °C	Pdh	5.3	kW
T _j = bivalent temperature	Pdh	12.1	kW
T _j = operation limit temperature	Pdh	11.1	kW
T _j = - 15 °C (if TOL < -20 °C)	Pdh	-	kW
Bivalent temperature	T biv	-7	°C
Cycling interval capacity for heating	Pcych	-	kW
Degradation coefficient	Cdh	1	
Power consumption in modes other than active mode Off mode Thermostat-off mode Standby mode Crankcase heater mode	P _{OFF} P _{TO} P _{SB} P _{CK}	0.000 0.014 0.016 0.000	kW kW kW
Other items Capacity control Sound power level, indoors/outdoors	L _{WA}	variable 40/56	dB
Souria power iever, iriaoors/outdoors	****	6242	kWh
Annual energy consumption	Q_{HF}		

Seasonal space heating energy efficiency	η _s	178	%
Declared coefficient of performance for part load at indoor temptemperature Tj	erature 20	°C and outde	oor
$\begin{split} T_j &= -7 \text{ °C} \\ T_j &= +2 \text{ °C} \\ T_j &= +7 \text{ °C} \\ T_j &= +12 \text{ °C} \\ T_j &= \text{ bivalent temperature} \\ T_j &= \text{ bivalent temperature} \\ T_j &= \text{ operation limit temperature} \\ T_j &= -15 \text{ °C (if TOL < -20 °C)} \\ \text{Operation limit temperature} \\ \text{Cycling interval efficiency} \\ \text{Heating water operating limit temperature} \end{split}$	COP _d TOL COPcyc	2.9 4.3 6.1 7.3 2.9 2.610 - 70	°C
Supplementary heater Rated heat output Type of energy input	Psup	2.6 Electric	kW
Rated air flow rate, outdoors		5393	m ³ /h

η_{wh}	130	%
•		
Q _{fuel}	-	kWh
AFC	-	kWh
	52.5	°C
	260	- 1
	AFC	52.5

Application	Medium temperature
Climate conditions	Average

Rated heat output	Prated	13	kW
Declared capacity for heating for part load at indoor temperatu temperature Tj	re 20 °C and	d outdoor	
T _j = - 7 °C	Pdh	11.8	kW
T _j = + 2 °C	Pdh	7.5	kW
T _j = + 7 °C	Pdh	6.5	kW
T _j = + 12 °C	Pdh	5.7	kW
T _j = bivalent temperature	Pdh	11.8	kW
T _j = operation limit temperature	Pdh	10.7	kW
T _j = - 15 °C (if TOL < -20 °C)	Pdh	-	kW
Bivalent temperature	T_{biv}	-7	°C
Cycling interval capacity for heating	Pcych	-	kW
Degradation coefficient	Cdh	1	
Power consumption in modes other than active mode	_		
Off mode	P _{OFF}	0.000	kW
Thermostat-off mode	P _{TO}	0.014	kW
Standby mode	P _{SB}	0.016	kW
Crankcase heater mode	P _{CK}	0.000	kW
Other items			
Capacity control		variable	
Sound power level, indoors/outdoors	L WA	40/56	dB
Annual energy consumption	Q_{HE}	7670	kWh

Seasonal space heating energy efficiency	η _s	141%	%
Declared coefficient of performance for part load at indoor temperature Tj	erature 20	°C and outd	loor
$\begin{split} T_j &= -7 \text{ °C} \\ T_j &= +2 \text{ °C} \\ T_j &= +7 \text{ °C} \\ T_j &= +12 \text{ °C} \\ T_j &= \text{ bivalent temperature} \\ T_j &= \text{ operation limit temperature} \\ T_j &= -15 \text{ °C (if TOL < -20 °C)} \\ Operation limit temperature \\ Cycling interval efficiency \\ Heating water operating limit temperature \\ Cycling interval efficiency \\ Heating water operating limit temperature \\ \end{split}$	COP _d TOL COPcyc	2.3 3.4 4.8 6.3 2.3 2.1 - -10 - 70	င့
Supplementary heater Rated heat output Type of energy input	Psup	2.6 Electric	kW
Rated air flow rate, outdoors		5393	m³/h

For heat pump combination heater							
Declared load profile		XL		Water heating energy efficiency	η_{wh}	130%	%
Daily electric consumption	Q elec	5788	kWh	Daily fuel consumption	Q fuel	-	kWh
Annual electricity consumption	AEC	1273	kWh	Annual fuel consumption	AFC	-	kWh
Standby cylinder heat loss		1200	Wh/day	Reference hot water temperature		52.5	°C
				DHW volume accounted for in test		260	- 1